



Centre d'Essais de Fontaine
17, Boulevard Paul Langevin
93600 FONTAINE - France
Tel. +33(0)4.76.53.42.12
Fax +33(0)4.76.53.22.49
Lab05@apave.com

CERTIFICATE OF CONFORMITY

N° 4401488-2

I. APPLICANT

- > Applicant : Mr Philip HIGGS
- > Copant name : KEE SAFETY Ltd, 1 Boulton Road, Reading, Berkshire RG2 0NH-UK

II. DESCRIPTION

- > Manufacturer: KEE SAFETY Ltd
- > Reference : KEEGUARD 040808-SK1
- > Category of equipment: Railguard

The railguard KEEGUARD 040808-SK1 is made of following components:

- 1 handrail of 6600mm with reference 8-6-G
- 1 intermediate rail of 6600mm with reference 8-6-G
- 4 stanchions with reference KGU35
- 2 foot with 2 counterweight with reference CB2P
- 2 central foot with 1 counterweight with reference CB1P

The railguard was made up of three identical lengths of 2200 mm. With 1100 mm high, it's installed against upstand.

IV. REFERENTIEL

The railguard KEEGUARD 040808-SK1 has been tested according to article 8.2 of the standard NF EN ISO 14122-3 :2007 and article 7.3.3.3 of the standard NFE 85-015 :2008 on a railguard with three identical lengths of 2200 mm.

V. CONCLUSION

The railguard KEEGUARD 040808-SK1, of manufacturer KEE SAFETY Ltd, is conform to tests described on article 8.2 of the standard EN ISO 14122-3 2007 and article 7.3.3.3 of the standard NFE 85-015 :2008 on a railguard with three identical lengths. Detailed description on the testing report 4401488-001-2.

The 24th October 2008
The Technical Manager

Guillaume QUINTIN

This certificate is included 1 page. 2 copies are delivered to the applicant

CETE APAVE SUDEUROPE

Société par Actions Simplifiée au Capital de 3 000 000 € - N° SIREN : 275 081 812 - Site Internet : www.apave.com
Locataire-gérant du fonds de commerce du CETE APAVE Lyonnais

LYON
177 rue de Saint Ives
BP 3
69611 TARDON CEDEX

MARSEILLE
8, rue Jean-Jacques Yvermasse
Z.A.C. Saumay-Bon... BP 199
13022 MARSEILLE CEDEX 18

BORDEAUX
21, avenue Guy Lussac
BP 3
33070 ARTIGUES-près-BORDEAUX